



EMSL Analytical, Inc.

200 Route 130 North Cinnaminson, NJ 08077

Tel/Fax: (800) 220-3675 / (856) 786-5974

<http://www.EMSL.com> / cinnasblab@EMSL.com

EMSL Order: 042004724

Customer ID: CRIT52

Customer PO:

Project ID:

Attention: Ian Forster
Criterion Laboratories, Inc.
400 Street Road
Bensalem, PA 19020

Phone: (215) 244-1300
Fax: (215) 244-4349
Received Date: 02/21/2020 16:20 PM
Analysis Date: 02/21/2020
Collected Date:

Project: School District of Philadelphia / Barton ES, 4600 Rosehill Street / 2nd and 3rd Floors

Test Report: Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Appendix A to Subpart E

Sample	Location	Volume (Liters)	Area Analyzed (mm ²)	Non Asb	Asbestos Type(s)	#Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration	
						≥0.5μ < 5μ	≥5μ		(S/mm ²)	(S/cc)
200424-002-20-01 042004724-0001	Room 300A - Back End	1902.72	0.0504	0	None Detected	0	0	0.0040	<20.00	<0.0040
200424-002-20-02 042004724-0002	Room 300A - Front End by Entrance	1892.81	0.0504	0	None Detected	0	0	0.0040	<20.00	<0.0040
200424-002-20-03 042004724-0003	Classroom 304 - Corner of W2/W3	1882.90	0.0504	0	None Detected	0	0	0.0041	<20.00	<0.0041
200424-002-20-04 042004724-0004	Classroom 304 - Corner of W3/W4	1882.90	0.0504	0	None Detected	0	0	0.0041	<20.00	<0.0041
200424-002-20-05 042004724-0005	Classroom 307 - W3 Center of Wall	1882.90	0.0504	0	None Detected	0	0	0.0041	<20.00	<0.0041
200424-002-20-06 042004724-0006	Classroom 309 - Center of Classroom	1843.26	0.0504	0	None Detected	0	0	0.0041	<20.00	<0.0041
200424-002-20-07 042004724-0007	Classroom 310 - Teachers Desk	1833.35	0.0504	0	None Detected	0	0	0.0042	<20.00	<0.0042
200424-002-20-08 042004724-0008	Classroom 310 - W2 Center (Close to Middle of Room)	1823.44	0.0504	0	None Detected	0	0	0.0042	<20.00	<0.0042
200424-002-20-09 042004724-0009	Classroom 311 - Center of Room	1833.35	0.0504	1	None Detected	0	0	0.0042	<20.00	<0.0042
200424-002-20-10 042004724-0010	Room 312A - Front End by Entrance	1803.62	0.0504	0	None Detected	0	0	0.0042	<20.00	<0.0042
200424-002-20-11 042004724-0011	Room 312A - Back End	1803.62	0.0504	0	None Detected	0	0	0.0042	<20.00	<0.0042
200424-002-20-12 042004724-0012	2nd Floor Hallway - South End - Between Classrooms 204 and 203	1833.35	0.0504	0	None Detected	0	0	0.0042	<20.00	<0.0042
200424-002-20-13 042004724-0013	2nd Floor Hallway - North End - by Water Fountain North End	1843.26	0.0504	0	None Detected	0	0	0.0041	<20.00	<0.0041

Initial report from: 02/21/2020 22:53 PM



EMSL Analytical, Inc.

200 Route 130 North Cinnaminson, NJ 08077

Tel/Fax: (800) 220-3675 / (856) 786-5974

<http://www.EMSL.com> / cinnasblab@EMSL.com

EMSL Order: 042004724
Customer ID: CRIT52
Customer PO:
Project ID:

Attention: Ian Forster Criterion Laboratories, Inc. 400 Street Road Bensalem, PA 19020	Phone: (215) 244-1300 Fax: (215) 244-4349 Received Date: 02/21/2020 16:20 PM Analysis Date: 02/21/2020 Collected Date:
Project: School District of Philadelphia / Barton ES, 4600 Rosehill Street / 2nd and 3rd Floors	

Test Report: Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Appendix A to Subpart E

Sample	Location	Volume (Liters)	Area		Asbestos Type(s)	#Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration	
			Analyzed (mm ²)	Non Asb		≥0.5μ < 5μ	≥5μ		(S/mm ²)	(S/cc)

Analyst(s)

Kurt Carlson (13)

Samantha Rundstrom, Laboratory Manager
or other approved signatory

EMSL maintains liability limited to cost of analysis. This report relates only to the samples reported above and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. This report must not be used to claim product certification, approval, or endorsement by NVLAP, NIST, or any agency of the federal government. EMSL is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. Samples received in good condition unless otherwise noted. The test results meet the requirements of NELAC unless otherwise noted. Estimated accuracy, precision and uncertainty data available upon request.

Samples analyzed by EMSL Analytical, Inc. Piscataway, NJ

Initial report from: 02/21/2020 22:53 PM